

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-1214:104 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Alarm-Saf, 65A Industrial Way, Wilmington, MA 01887-3499
Contact: * Michael Bone (978) 658-6717 Fax (978) 658-8638

DESIGN: Models CD4-NPL-B01-UL/CSA/ULC and CD4-PLS-B01-UL/CSA/ULC power distribution unit. The unit is intended for use to distribute the output of a listed power supply into four separate outputs. The unit may also be interconnected to a listed fire alarm control unit through a notification loop to sense an alarm condition. Upon a fire alarm condition, the reversal of polarity is sensed by the unit and the outputs are then de-energized, thereby releasing the control devices. Refer to listee's data sheet for additional detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating and UL label.

APPROVAL: Listed as control unit accessories to distribute power to egress controls mag locks, door closer/holders.

*Rev. 06-23-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 23, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**